


- RUN TIME SAFETY SELECT:**
 28.8 SECONDS: SWITCHES 1 AND 2 "ON"
 45 SECONDS: SWITCH 1 "OFF", SWITCH 2 "ON"
 60 SECONDS: SWITCHES 1 AND 2 "OFF"
 92.13 SECONDS: SWITCH 1 "ON", SWITCH 2 "OFF"
 #3 DIPSWITCH MUST BE SET TO "ON"



- (A) WIRE IS NOT USED WHEN EXTERNAL INTERLOCK SWITCH OR STOP BUTTON IS USED
- (B) OBSTRUCTION SENSING DEVICES MAY BE N.O. TYPE (STANDARD AIR SWITCH, ELECTRIC EDGE, ETC.)
- (C) SHADOW LOOP DETECTOR CONTACT (N.O.) WHEN GATE IS IN FULLY OPEN POSITION.

UNITS SHIPPED AS RIGHT HAND, FOR LEFT HAND, SWITCH Y & BL MOTOR LEADS AT CONTACTOR!

PowerMaster	
MODEL CSW/C, CSW4	SS6 TPU MODULE-1 Ø
DATE: 11-27-02	REV. 11
BY: F.S.	
CAP START MOTOR WSWITCH	
WIRING DIAGRAM 5531 DR	

© Copyright PowerMaster 1997
 No portion of this diagram may be reproduced without the expressed written permission of the manufacturer.