



FOR MOMENTARY PRESSURE CLOSE, MOVE THIS RED WIRE TO TERMINAL # 5

ALL CONTROL WIRING IS 115V

- NOTES:
- 1- WIRE-NOT FURNISHED WHEN EXTERNAL INT'LK SWITCH IS USED. - NOT FURNISHED WHEN STOP BUTTON IS USED.
 - 2- WIRE-NOT FURNISHED WHEN TIMER DEFEAT SWITCH IS USE.
 - A-TREADLES, PULL SWITCHES, KEY SWITCHES, PHOTO-ELECTRIC DEVICES, ECT. MAY BE CONNECTED TO TERMINALS INDICATED
 - B-REMOTE CONTROL UNITS (EXCLUDING TREADLES AND PHOTO-ELECTRIC UNITS). PULL SWITCHES AND SINGLE CONTACT CONTROL STATIONS, MAY BE CONNECTED TO TERMINALS INDICATED.

OBSTRUCTION SENSING DEVICE (24V)
(KEEP SEPARATE FROM ALL OTHER WIRING)

INCOMING LINE
L2-HOT LEG
L1-NEUTRAL

WIRED FOR 115V, 1Ø

| | |
|--|--------|
| PowerMaster | |
| WIRING TYPE: SAFETY EDGE TO REVERSE WITH OPTIONAL TIMER | |
| MTR/CNTR: 1Ø | |
| DATE: 1-6-99 | REV. 0 |
| BY: F.S. | |
| SPECIAL: 115 VAC CONTROL 24V S.E. | |
| WIRING DIAGRAM NO. 331-A1PD | |
| © Copyright PowerMaster 1997 No portion of this diagram may be reproduced without the expressed written permission of the manufacturer. | |